



Borough of  
Tinton Falls  
New Jersey

FIRE PREVENTION BUREAU

556 TINTON AVENUE  
TINTON FALLS, NJ 07724-3298  
PHONE #: 732-542-3400 EXT. 238

# MEMORANDUM

Date: June 11, 2020  
To: Trish Sena, Planning Board Secretary  
RE: PB 2020-09



FROM: Cary Costa, Fire Marshal

In regards to the above referenced project, I have the following comments:

1. All cart ways & roadways shall be marked Fire Lanes as per Borough Ordinance.
2. Second driveway extended to West Park Avenue shall be used as Emergency Access Only.
3. Fire hydrant placement shall be done when FDC placement on building is established.
4. Private third-party contractor shall be required for Ambulance Service.

  
*Cary Costa, Fire Marshal*